



VERTICAL ROUND INSULATED/JACKETED ASME 125 PSI TANK - OPTIMIZED FOR SPLIT SYSTEM HPWH

Job Name _____

Location _____

Engineer _____

Wholesaler _____

Mech. Contractor _____

Model No. _____

Gallon Capacity _____

Equipment Tag(s) _____

Notes _____

STANDARD FEATURES:

- Five (5) year limited warranty
- 125 PSI working pressure
- Jacketed and R30 insulated
- Unique baffle design
- Proprietary stratification design

FACTORY JACKETED AND INSULATED STORAGE TANKS

These State heat pump storage tanks are optimized for heat pump DHW applications requiring long duration recovery periods.

FEATURES

Heat pump DHW production often relies on minimal input and full utilization of off-peak periods to heat the stored water. These tanks are designed to take full advantage of these systems by reducing turbulence and providing unprecedented stratification. The proprietary stratification system employs a unique baffle that arrests water velocity into and out of the tank to prevent disruption of the stratified layers. An impressive R30 insulation value helps retain heat until it is demanded by the system. Draw down of 95% sets these tanks apart from others, delivering more hot water from a given capacity.

FOUR MODELS

- 250-gallons
- 450-gallons
- 650-gallons
- 850-gallons

GLASS-LINED TANK

- Alkaline borosilicate composition permanently fused to steel by firing at a temperature of 1600°F, providing years of corrosion protection and dependable use

ANODE PROTECTION

- Furnished with magnesium anodes for additional anti-corrosion protection

HEAVY GAUGE STEEL JACKET

- The jacket is constructed from heavy gauge galvanized steel, primed and painted on both sides

THREADED OPENINGS

- Furnished with two 3" bolted flange circulating connections, one 1-1/4" NPT relief valve connection, four 3/4" NPT aquastat openings and one 1" NPT drain connection

INSULATION

- Completely encased in a minimum of 5" thick, high density polyurethane foam insulation and have an insulating value of R30, exceeding the minimum thermal insulation requirements of the U. S. Department of Energy and current edition of ASHRAE/IESNA 90.1

ASME TANK CONSTRUCTION

- Constructed in accordance with ASME Boiler and Pressure Vessel Code requirements, and "HLW" stamped and registered with the National Board of Boiler and Pressure Vessel Inspectors
- 125 PSI ASME standard working pressure

5 YEAR WARRANTY


- If the tank should leak any time during the first 5 years, under the terms of the warranty, State will repair or replace the tank. Installation, labor, handling and local delivery are extra. For complete information, consult the written warranty.


ASME

SOLID. STATE.

RECOVERY CAPACITIES

Model Number	Rated Storage Capacity (Gallons)	A	B	C	D	Shipping Weight
PVHP-0250-00VTA125	250	99-1/2"	40"	19-1/2"	95"	1,180
PVHP-0500-00VTA125	450	100"	52"	23"	95-1/2"	1,726
PVHP-0750-00VTA125	650	136"	52"	23"	131-1/2"	2,911
PVHP-1000-00VTA125	850	137"	58"	25"	132-1/2"	3,458



SUGGESTED SPECIFICATION

Storage tank shall be State tank, Model _____ with vertical construction having a storage capacity of _____ gallons. The tank shall be constructed with an inner chamber baffle designed to receive all circulation to and from the water heater to eliminate turbulence in the tank. The baffled tank shall supply 95% of tank capacity without a drop in outlet temperature, regardless of rate of draw.

Storage tank shall be constructed in accordance with ASME Boiler and Pressure Vessel Code requirements, and "HLW" stamped and registered with the National Board of Boiler and Pressure Vessel Inspectors. The tank shall be furnished with the following connections: two 3" bolted flange circulating connections, one 1-1/4" NPT relief valve connection, four 3/4" NPT aquastat openings and one 1" NPT drain connection. The tank shall be furnished with a man-way for ease of inspection, clean-out and service.

Storage tank shall have a working pressure of 125 PSI. The interior of the storage tank shall be glass-lined and fired to 1600o F to ensure a molecular fusing of glass and steel. Storage tank shall be furnished with magnesium anodes. Storage tank shall have a five (5) year limited warranty as outlined in the written warranty.

The storage tank shall be constructed with a heavy gauge galvanized steel jacket assembly, primed and painted on both sides with a minimum dry film thickness of 0.70 mills. The storage tank shall be completely encased in a minimum of 5" thick, high density polyurethane foam insulation and have an insulating value of R30.

The jacket dimensions shall be _____" wide, _____" deep and _____" high.